October 2, 2023

BID BULLETIN NO. 2023-04

Expansion and Improvement of General Santos Fish Port Complex Package 2 (Design and Build)

This Bid Bulletin is issued to revise, amend, and harmonize the Minimum Performance Standards and Specifications (MPSS) Provisions (Section 2 Basic Configuration and Section 5.9 Mechanical System), to wit:

5. 9 Mechanical System:

D. Equipment Selection

2. Refrigeration System

The factory assembled equipment are as follows:

The ammonia compressor to use is reciprocating type or screw type.

To be revised to:

This Bid Bulletin is issued to revise, amend, and harmonize the Minimum Performance Standards and Specifications (MPSS) Provisions (Section 2 Basic Configuration and Section 5.9 Mechanical System), to wit:

5. 9 Mechanical System:

D. Equipment Selection

2. Refrigeration System

The factory assembled equipment are as follows:

The ammonia compressor to use is reciprocating type.

For any inquiries and questions, you may call us at (02) 89256146 or send us an email to bac.co@pfda.gov.ph

For the guidance and information of all concerned.









PCA Annex Building Elliptical Road Diliman, Q.C. Telefax. No. 8925-61-41 www.pfda.gov.ph

